



PUBLIC NOTICE

Westfield Fire District  
653 East Street, Middletown, CT 06457  
860-632-2690 / phone 860-632-0536 / fax  
[wfdadmin@westfieldfd.com](mailto:wfdadmin@westfieldfd.com)

---

## **Request for Proposal (RFP #2017-001)**

---

Release Date: July 15, 2017

Contact Name:  
Linda DeManche / Fire District Administrator

---

# RFP #2017-001 – BREATHING AIR COMPRESSOR, CASCADE, FILL STATION, AND INSTALLATION

## Addendum No.1

---

### Request for Interpretation – Electrical Power

**Question:** Is it single phase or three phase? **Three Phase**

**Question:** Which voltage is it: 208 / 230 / 460? **208**

**Question:** When the new compressor is installed, is it up to the customer to have an electrician on-hand to disconnect the old unit and connect the new unit?

- **NO**
- **The electrical disconnect of the existing compressor and electrical connection of the new compressor is eliminated from the scope of work.**

### Installation – (page 7) shall now read

Remove or relocate on-site (Westfield’s option) the existing Ingersoll Rand breathing air compressor, set up new compressor fill station and bottles in existing location, tie into existing electrical disconnect, perform start-up on unit, bring up online.

---

### Acknowledgement of Receipt

Date: \_\_\_\_\_

Firm: \_\_\_\_\_

Signature: \_\_\_\_\_

Address: \_\_\_\_\_

Print Name: \_\_\_\_\_

\_\_\_\_\_

Title: \_\_\_\_\_

Telephone: \_\_\_\_\_