



PUBLIC NOTICE

Westfield Fire District  
653 East Street, Middletown, CT 06457  
860-632-2690 / phone 860-632-0536 / fax  
[wfdadmin@westfieldfd.com](mailto:wfdadmin@westfieldfd.com)

---

## **Request for Proposal (RFP #2017-001)**

---

Release Date: July 15, 2017

Contact Name:  
Linda DeManche / Fire District Administrator

---

# RFP #2017-001 – BREATHING AIR COMPRESSOR, CASCADE, FILL STATION, AND INSTALLATION

## Addendum No. 2

---

**Reason: Revision to requirement specifications**

**Requirements – (page 6) shall now read**

Requirements

1. Compressor shall be a minimum 6000 psi, 15 horsepower, capable of producing Class D breathing air.
2. Cascade system shall be an ASME system rated for 6000 psi, with a regulator to allow filling of 4500 psi DOT bottles on Westfield’s ariel apparatus.
3. SCBA fill station/containment system shall be capable of holding a minimum of three 45 minute, 5500 psi SCBA cylinders for refilling purposes.
4. One (1) integrated combo CO and moisture monitor.
5. Four (4) 6000 psi ASME storage cylinders
- 6. Soft Starter Package**

Bidders are instructed that these specifications are the minimum acceptable specifications. Any specifications or features that exceed these minimum specifications are to be documented and detailed separately under a heading: **ADDITIONAL SPECIFICATION DETAILS**. Anyone who submits specifications that do not meet these minimums will be disqualified.

---

### Acknowledgement of Receipt

Date: \_\_\_\_\_

Firm: \_\_\_\_\_

Signature: \_\_\_\_\_

Address: \_\_\_\_\_

Print Name: \_\_\_\_\_

\_\_\_\_\_

Title: \_\_\_\_\_

Telephone: \_\_\_\_\_